

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Thursday, July 16, 2015 6:21 PM
To: david.burns@state.ma.us; Turin, David; Joyce, Ryan (FWE)
Cc: 'Dow, James' (jdow@town.hull.ma.us) (jdow@town.hull.ma.us); Frank Cavaleri
Subject: SSO - Station 9 - 165 Main Street

Good afternoon.

I am reporting this SSO, which was the result of our setting up and testing of a portable trash pump at Pump Station #9. The spill of approximately 10-15 gallons occurred at approximately 3:30pm. The pump was set up to serve as an emergency back-up pump, since one of the pump station pumps is out of service, due to a broken pump shaft. The release was onto the asphalt parking area. No sewage made it to the storm drain. The required SSO form will follow. Voice Messages were left for the MA DEP, US EPA, and Div of Marine Fisheries.

Please contact me should you have any additional questions.

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS